

**Table 1. NYC Department of Environmental Protection  
Lead and Copper Selection Criteria and All First Draw Results  
for the compliance period of 2014 and the monitoring period of June - September 2014**

Bottle ID Number	KIT ID Number	Site ID Number	Address of Sampling Site	Borough	Zipcode	Criteria for Inclusion*	Date Collected	Received Date	First Draw at-the-tap Lead level (µg/l)	First Draw at-the-tap copper level (mg/l)
AL-45443	1410001	697EPA029		Queens	11378	Lead	6/16/2014	6/17/2014	8	0.114
AL-45444	1410002	697EPA138		Queens	11354	Lead	6/16/2014	6/20/2014	14	0.134
AL-45446	1410004	697EPA267		Brooklyn	11223	Lead	6/10/2014	6/11/2014	9	0.126
AL-45447	1410005	697EPA274		Brooklyn	11215	Lead	6/12/2014	6/16/2014	5	0.153
AL-45448	1410006	94L0038		Queens	11361	Lead	6/8/2014	6/10/2014	2	0.203
AL-45449	1410007	97AEPA136		New York	10010	Copper / Pb solder	6/7/2014	6/12/2014	0	0.143
AL-45450	1410008	997EPA067		Staten Island	10308	Copper / Pb solder	6/9/2014	6/12/2014	1	0.113
AL-45451	1410009	997EPA146		Staten Island	10306	Copper / Pb solder	6/16/2014	6/23/2014	0	0.082
AL-45452	1410010	997EPA483		Brooklyn	11224	Copper / Pb solder	6/13/2014	6/16/2014	0	0.136
AL-45453	1410011	997EPA553		Bronx	10457	Copper / Pb solder	6/9/2014	6/10/2014	0	0.156
AL-45454	1410012	EPA050004		Queens	11423	Lead	6/9/2014	6/11/2014	14	0.067
AL-45455	1410013	EPA050018		Brooklyn	11230	Lead	6/11/2014	6/16/2014	7	0.196
AL-45456	1410014	EPA050024		Queens	11415	Copper / Pb solder	6/24/2014	6/27/2014	0	0.040
AL-45457	1410015	EPA050035		Staten Island	10314	Copper / Pb solder	6/11/2014	6/12/2014	0	0.108
AL-45458	1410016	EPA050056		Queens	11433	Lead	6/10/2014	6/16/2014	0	0.184
AL-45459	1410017	EPA050068		Queens	11415	Lead	6/8/2014	6/11/2014	0	0.061
AL-45460	1410018	EPA050069		Queens	11411	Lead	8/8/2014	8/12/2014	0	0.091
AL-45461	1410019	EPA050085		Queens	11433	Copper / Pb solder	6/11/2014	6/12/2014	0	0.113
AL-45462	1410020	EPA060001		Staten Island	10303	Copper / Pb solder	6/9/2014	6/10/2014	0	0.153
AL-45463	1410021	EPA060009		Queens	11412	Lead	7/24/2014	7/28/2014	2	0.042
AL-45464	1410022	EPA060025		Queens	11434	Lead	6/11/2014	6/12/2014	0	0.172
AL-45465	1410023	EPA060039		Bronx	10457	Copper / Pb solder	6/20/2014	6/24/2014	0	0.049
AL-45468	1410026	EPA060071		Queens	11412	Lead	6/18/2014	6/23/2014	1	0.144
AL-45469	1410027	EPA060079		Queens	11415	Lead	6/10/2014	6/12/2014	2	0.092
AL-45470	1410028	EPA060085		Queens	11432	Lead	6/18/2014	6/19/2014	422	0.420
AL-45471	1410029	EPA070001		Queens	11432	Lead	6/9/2014	6/11/2014	1	0.081
AL-45472	1410030	EPA070012		Queens	11414	Copper / Pb solder	6/10/2014	6/13/2014	0	0.107
AL-45474	1410032	EPA070025		Queens	11420	Lead	6/11/2014	6/16/2014	0	0.110
AL-45477	1410035	EPA070042		Queens	11435	Lead	6/23/2014	6/24/2014	2	0.074
AL-45478	1410036	EPA080012		Queens	11419	Lead	6/12/2014	6/16/2014	2	0.114
AL-45483	1410041	EPA090001		Brooklyn	11224	Copper / Pb solder	6/12/2014	6/16/2014	0	0.048
AL-45484	1410042	EPA090003		Brooklyn	11212	Copper / Pb solder	6/13/2014	6/16/2014	7	0.200

\*Lead = Lead service line

Copper/Pb solder = Copper pipes joined by lead solder installed after 1982.

° See Table 2. Lead and copper compliance samples NOT invalidated but questionable. 10/10/2014

**Table 1. NYC Department of Environmental Protection  
Lead and Copper Selection Criteria and All First Draw Results  
for the compliance period of 2014 and the monitoring period of June - September 2014**

Bottle ID Number	KIT ID Number	Site ID Number	Address of Sampling Site	Borough	Zipcode	Criteria for Inclusion*	Date Collected	Received Date	First Draw at-the-tap Lead level (µg/l)	First Draw at-the-tap copper level (mg/l)
AL-45485	1410043	EPA090004		Brooklyn	11213	Copper / Pb solder	6/22/2014	6/27/2014	0	0.093
AL-45486	1410044	EPA090005		Brooklyn	11212	Copper / Pb solder	6/10/2014	6/19/2014	0	0.141
AL-45487	1410045	EPA090008		Staten Island	10301	Lead	6/10/2014	6/12/2014	6	0.176
AL-45488	1410046	EPA090011		Queens	11363	Lead	6/11/2014	6/12/2014	0	0.159
AL-45489	1410047	EPA090013		Bronx	10457	Lead	6/12/2014	6/16/2014	5	0.154
AL-45490	1410048	EPA090023		Bronx	10470	Lead	6/16/2014	6/23/2014	6	0.104
AL-45491	1410049	EPA090032		Brooklyn	11234	Lead	6/14/2014	6/23/2014	7	0.035
AL-45493	1410051	EPA090035		Queens	11423	Lead	6/18/2014	6/19/2014	1	0.139
AL-45495	1410053	EPA090043		Queens	11102	Lead	6/9/2014	6/10/2014	7	0.118
AL-45496	1410054	EPA090044		Brooklyn	11234	Copper / Pb solder	6/18/2014	6/19/2014	0	0.222
AL-45497	1410055	EPA090045		Queens	11419	Lead	6/9/2014	6/10/2014	5	0.089
AL-45498	1410056	EPA100003		Bronx	10461	Lead	6/8/2014	6/10/2014	6	0.132
AL-45499	1410057	EPA100004		Brooklyn	11201	Lead	6/12/2014	6/13/2014	3	0.142
AL-45500	1410058	EPA100005		Queens	11418	Lead	6/20/2014	6/24/2014	2	0.014
AL-45501	1410059	EPA100006		Queens	11419	Lead	6/13/2014	6/20/2014	7	0.201
AL-45502	1410060	EPA100008		Brooklyn	11234	Lead	6/23/2014	6/27/2014	0	0.069
AL-45504	1410062	EPA100011		New York	10013	Lead	6/16/2014	6/18/2014	5	0.077
AL-45505	1410063	EPA100012		Queens	11354	Lead	6/23/2014	6/26/2014	17	0.092
AL-45507	1410065	EPA110007		Brooklyn	11205	Lead	6/26/2014	6/30/2014	5	0.170
AL-45508	1410066	EPA110009		Brooklyn	11215	Lead	6/26/2014	6/30/2014	5	0.403
AL-45509	1410067	EPA110010		Queens	11377	Lead	6/10/2014	6/16/2014	18	0.103
AL-45510	1410068	EPA110013		Brooklyn	11228	Lead	6/9/2014	6/18/2014	24	0.155
AL-45511	1410069	EPA110015		Staten Island	10301	Lead	6/12/2014	6/16/2014	7	0.125
AL-45512	1410070	EPA110017		Queens	11001	Lead	8/17/2014	8/20/2014	6	0.145
AL-45514	1410072	EPA110023		Brooklyn	11234	Lead	6/20/2014	6/27/2014	2	0.004
AL-45517	1410075	EPA110033		Bronx	10464	Lead	6/16/2014	6/17/2014	4	0.160
AL-45518	1410076	EPA110034		Queens	11361	Lead	6/17/2014	6/26/2014	2	0.149
AL-45520	1410078	EPA110036		Brooklyn	11204	Lead	6/12/2014	6/16/2014	16	0.223
AL-45522	1410080	EPA110038		Bronx	10464	Lead	6/10/2014	6/17/2014	11	0.145
AL-45524	1410082	EPA110040		Queens	11375	Lead	6/15/2014	6/17/2014	1	0.097
AL-45525	1410083	EPA110041		Queens	11375	Lead	6/10/2014	6/12/2014	7	0.065
AL-45527	1410085	EPA110043		Queens	11358	Lead	6/13/2014	6/16/2014	4960	0.430

\*Lead = Lead service line

Copper/Pb solder = Copper pipes joined by lead solder installed after 1982.

Ø See Table 2. Lead and copper compliance samples NOT invalidated but questionable. 10/10/2014

**Table 1. NYC Department of Environmental Protection  
Lead and Copper Selection Criteria and All First Draw Results  
for the compliance period of 2014 and the monitoring period of June - September 2014**

Bottle ID Number	KIT ID Number	Site ID Number	Address of Sampling Site	Borough	Zipcode	Criteria for Inclusion*	Date Collected	Received Date	First Draw at-the-tap Lead level (µg/l)	First Draw at-the-tap copper level (mg/l)
AL-45529	1410087	EPA110045		Queens	11373	Lead	6/9/2014	6/10/2014	11	0.158
AL-45530	1410088	EPA110049		Queens	11355	Lead	6/22/2014	6/25/2014	2	0.043
AL-45532	1410090	EPA110053		Queens	11379	Lead	6/15/2014	6/23/2014	9	0.156
AL-45533	1410091	EPA110054		Queens	11432	Lead	6/12/2014	6/16/2014	10	0.141
AL-45534	1410092	EPA110055		Queens	11385	Lead	6/7/2014	6/16/2014	19	0.089
AL-45535	1410093	EPA110056		Queens	11378	Lead	6/11/2014	6/16/2014	23	0.070
AL-45536	1410094	EPA110057		Queens	11358	Lead	6/10/2014	6/16/2014	8	0.162
AL-45537	1410095	EPA110058		Queens	11379	Lead	6/17/2014	6/19/2014	4	0.062
AL-45538	1410096	EPA110059		Queens	11354	Lead	6/11/2014	6/13/2014	5	0.225
AL-45539	1410097	EPA110060		Queens	11361	Lead	6/22/2014	6/25/2014	4	0.117
AL-45540	1410098	EPA110061		Staten Island	10314	Lead	6/17/2014	6/20/2014	5	0.123
AL-45541	1410099	EPA110062		Queens	11375	Lead	6/16/2014	6/17/2014	5	0.040
AL-45542	1410100	EPA110064		Queens	11358	Lead	6/8/2014	6/11/2014	19	0.150
AL-45543	1410101	EPA110065		Queens	11354	Lead	7/11/2014	7/15/2014	1	0.185
AL-45544	1410102	EPA110067		Queens	11432	Lead	6/11/2014	6/16/2014	2	0.035
AL-45545	1410103	EPA110069		Queens	11358	Lead	6/9/2014	6/10/2014	8	0.107
AL-45546	1410104	EPA110070		Queens	11354	Lead	6/9/2014	6/17/2014	4	0.189
AL-45547	1410105	EPA110073		Queens	11358	Lead	6/15/2014	6/17/2014	1	0.093
AL-45548	1410106	EPA110074		Queens	11354	Lead	7/19/2014	7/28/2014	4	0.193
AL-45550	1410108	EPA110077		Queens	11378	Lead	6/12/2014	6/16/2014	7	0.086
AL-45551	1410109	EPA110078		Queens	11363	Lead	6/11/2014	6/16/2014	10	0.119
AL-45552	1410110	EPA110079		Queens	11362	Lead	6/13/2014	6/17/2014	5	0.139
AL-45553	1410111	EPA110080		Queens	11432	Lead	6/11/2014	6/16/2014	0	0.056
AL-45554	1410112	EPA110081		Queens	11385	Lead	6/13/2014	6/16/2014	3	0.119
AL-45557	1410115	EPA110088		Staten Island	10304	Lead	7/8/2014	7/10/2014	8	0.108
AL-45558	1410116	EPA110089		Queens	11358	Lead	6/12/2014	6/16/2014	4	0.177
AL-45560	1410118	EPA110091		Queens	11378	Lead	6/8/2014	6/10/2014	4	0.107
AL-45561	1410119	EPA110092		Queens	11385	Lead	8/15/2014	8/18/2014	5	0.042
AL-45563	1410121	EPA110094		Queens	11691	Copper / Pb solder	7/13/2014	7/15/2014	2	0.089
AL-45564	1410122	EPA110095		Queens	11385	Lead	7/13/2014	7/16/2014	5	0.027
AL-45566	1410124	EPA110097		Brooklyn	11224	Copper / Pb solder	6/11/2014	6/12/2014	0	0.136
AL-45567	1410125	EPA110101		Brooklyn	11207	Copper / Pb solder	6/10/2014	6/13/2014	0	0.053

\*Lead = Lead service line

Copper/Pb solder = Copper pipes joined by lead solder installed after 1982.

° See Table 2. Lead and copper compliance samples NOT invalidated but questionable. 10/10/2014

**Table 1. NYC Department of Environmental Protection  
Lead and Copper Selection Criteria and All First Draw Results  
for the compliance period of 2014 and the monitoring period of June - September 2014**

Bottle ID Number	KIT ID Number	Site ID Number	Address of Sampling Site	Borough	Zipcode	Criteria for Inclusion*	Date Collected	Received Date	First Draw at-the-tap Lead level (µg/l)	First Draw at-the-tap copper level (mg/l)
AL-45568	1410126	EPA110103		Brooklyn	11223	Lead	6/18/2014	6/20/2014	6	0.137
AL-45569	1410127	EPA110104		Queens	11385	Lead	7/9/2014	7/15/2014	9	0.034
AL-45570	1410128	EPA110105		Queens	11375	Lead	6/9/2014	6/10/2014	5	0.113
AL-45572	1410130	EPA110108		Queens	11691	Lead	6/11/2014	6/13/2014	1	0.231
AL-45573	1410131	EPA110109		Queens	11369	Lead	6/19/2014	6/20/2014	8	0.194
AL-45574	1410132	EPA110111		Queens	11354	Lead	6/15/2014	6/23/2014	5	0.100
AL-45575	1410133	EPA110112		Brooklyn	11212	Copper / Pb solder	7/26/2014	7/30/2014	0	0.125
AL-45577	1410135	EPA110114		Brooklyn	11224	Copper / Pb solder	8/8/2014	8/11/2014	1	0.063
AL-45579	1410137	EPA110117		Queens	11357	Lead	6/11/2014	6/12/2014	7	0.123
AL-45581	1410139	EPA110124		Staten Island	10308	Copper / Pb solder	6/12/2014	6/20/2014	0	0.049
AL-45582	1410140	EPA110125		Staten Island	10306	Copper / Pb solder	6/8/2014	6/11/2014	0	0.124
AL-45583	1410141	EPA110126		Brooklyn	11212	Copper / Pb solder	6/24/2014	6/30/2014	2	0.192
AL-45584	1410142	EPA110128		Queens	11691	Copper / Pb solder	6/11/2014	6/13/2014	3	0.080
AL-45585	1410143	EPA110129		Staten Island	10309	Copper / Pb solder	6/8/2014	6/10/2014	0	0.098
AL-45586	1410144	EPA110130		Staten Island	10308	Copper / Pb solder	6/9/2014	6/10/2014	9	0.154
AL-45587	1410145	EPA110131		Staten Island	10306	Copper / Pb solder	6/8/2014	6/10/2014	1	0.136
AL-45588	1410146	EPA110132		Staten Island	10306	Copper / Pb solder	6/10/2014	6/12/2014	0	0.196
AL-45589	1410147	EPA110133		Staten Island	10312	Copper / Pb solder	6/15/2014	6/17/2014	0	0.081
AL-45590	1410148	EPA110134		Staten Island	10312	Copper / Pb solder	6/26/2014	7/2/2014	1	0.139
AL-45591	1410149	EPA110135		Staten Island	10314	Copper / Pb solder	6/14/2014	6/16/2014	0	0.147
AL-45592	1410150	EPA110136		Staten Island	10309	Copper / Pb solder	6/27/2014	6/30/2014	2	0.139
AL-45593	1410151	EPA110138		Staten Island	10312	Copper / Pb solder	6/25/2014	6/26/2014	0	0.089
AL-45594	1410152	EPA110139		Staten Island	10306	Copper / Pb solder	6/11/2014	6/16/2014	0	0.112
AL-45597	1410155	EPA110142		Staten Island	10308	Copper / Pb solder	6/12/2014	6/16/2014	0	0.063
AL-45598	1410156	EPA110143		Staten Island	10306	Copper / Pb solder	6/9/2014	6/11/2014	2	0.147
AL-45599	1410157	EPA110144		Staten Island	10306	Copper / Pb solder	6/13/2014	6/18/2014	0	0.224
AL-45600	1410158	EPA110145		Staten Island	10312	Copper / Pb solder	6/9/2014	6/11/2014	30	0.114
AL-45601	1410159	EPA110146		Staten Island	10308	Copper / Pb solder	6/9/2014	6/10/2014	2	0.104
AL-45602	1410160	EPA110147		Staten Island	10308	Copper / Pb solder	6/20/2014	6/24/2014	16	0.113
AL-45603	1410161	EPA110149		Staten Island	10306	Copper / Pb solder	6/7/2014	6/18/2014	1	0.145
AL-45604	1410162	EPA110150		Staten Island	10306	Copper / Pb solder	6/9/2014	6/11/2014	0	0.152
AL-45605	1410163	EPA110151		Staten Island	10305	Copper / Pb solder	6/10/2014	6/12/2014	0	0.104

\*Lead = Lead service line

Copper/Pb solder = Copper pipes joined by lead solder installed after 1982.

° See Table 2. Lead and copper compliance samples NOT invalidated but questionable. 10/10/2014

**Table 1. NYC Department of Environmental Protection  
Lead and Copper Selection Criteria and All First Draw Results  
for the compliance period of 2014 and the monitoring period of June - September 2014**

Bottle ID Number	KIT ID Number	Site ID Number	Address of Sampling Site	Borough	Zipcode	Criteria for Inclusion*	Date Collected	Received Date	First Draw at-the-tap Lead level (µg/l)	First Draw at-the-tap copper level (mg/l)
AL-45606	1410164	EPA110152		Staten Island	10303	Copper / Pb solder	6/10/2014	6/12/2014	0	0.110
AL-45607	1410165	EPA110153		Staten Island	10314	Copper / Pb solder	6/9/2014	6/12/2014	0	0.107
AL-45608	1410166	EPA110154		Staten Island	10314	Copper / Pb solder	6/12/2014	6/16/2014	0	0.161
AL-45609	1410167	EPA110155		Staten Island	10312	Copper / Pb solder	6/25/2014	6/27/2014	0	0.136
AL-45610	1410168	EPA110156		Staten Island	10312	Copper / Pb solder	6/9/2014	6/16/2014	0	0.119
AL-45611	1410169	EPA110157		Staten Island	10312	Copper / Pb solder	7/7/2014	7/9/2014	24	0.159
AL-45612	1410170	EPA110158		Staten Island	10307	Copper / Pb solder	6/10/2014	6/12/2014	0	0.197
AL-45613	1410171	EPA110159		Staten Island	10309	Copper / Pb solder	6/10/2014	6/12/2014	0	0.021
AL-45614	1410172	EPA110160		Staten Island	10312	Copper / Pb solder	6/10/2014	6/12/2014	0	0.107
AL-45615	1410173	EPA110162		Staten Island	10308	Copper / Pb solder	6/12/2014	6/16/2014	1	0.143
AL-45616	1410174	EPA110164		Staten Island	10304	Copper / Pb solder	6/17/2014	6/20/2014	4	0.126
AL-45617	1410175	EPA110165		Staten Island	10314	Copper / Pb solder	6/16/2014	6/16/2014	3	0.136
AL-45619	1410177	EPA110168		Staten Island	10306	Copper / Pb solder	6/8/2014	6/11/2014	4	0.158
AL-45620	1410178	EPA110169		Staten Island	10306	Copper / Pb solder	6/13/2014	6/17/2014	0	0.150
AL-45621	1410179	EPA110170		Staten Island	10309	Copper / Pb solder	6/16/2014	6/18/2014	0	0.194
AL-45622	1410180	EPA110171		Staten Island	10314	Copper / Pb solder	6/10/2014	6/16/2014	2	0.250
AL-45623	1410181	EPA110172		Staten Island	10314	Copper / Pb solder	6/23/2014	6/25/2014	0	0.084
AL-45625	1410183	EPA110174		Staten Island	10309	Copper / Pb solder	6/14/2014	6/17/2014	0	0.161
AL-45627	1410185	EPA110176		Staten Island	10309	Copper / Pb solder	6/10/2014	6/12/2014	0	0.077
AL-45629	1410187	EPA110183		Staten Island	10306	Copper / Pb solder	6/25/2014	6/30/2014	6	0.151
AL-45631	1410189	EPA110185		Staten Island	10304	Copper / Pb solder	6/8/2014	6/10/2014	26	0.164
AL-45634	1410192	EPA110189		Staten Island	10314	Copper / Pb solder	6/13/2014	6/16/2014	1	0.159
AL-45635	1410193	EPA110190		Staten Island	10314	Copper / Pb solder	6/8/2014	6/12/2014	1	0.162
AL-45638	1410196	EPA110194		Queens	11379	Lead	6/17/2014	6/18/2014	7	0.192
AL-40991	13100232	EPA110195		Queens	11358	Lead	6/8/2014	6/11/2014	7	0.125
AL-45639	1410197	EPA110195		Queens	11358	Lead	7/8/2014	7/9/2014	11	0.095
AL-45640	1410198	EPA110198		Bronx	10465	Lead	6/11/2014	6/16/2014	5	0.145
AL-45641	1410199	EPA110199		Brooklyn	11218	Lead	6/30/2014	7/1/2014	7	0.146
AL-45642	1410200	EPA110200		Queens	11360	Copper / Pb solder	6/14/2014	6/17/2014	0	0.126
AL-45643	1410201	EPA120002		Staten Island	10305	Copper / Pb solder	6/7/2014	6/12/2014	0	0.051
AL-45644	1410202	EPA120003		Staten Island	10305	Copper / Pb solder	6/12/2014	6/16/2014	0	0.156
AL-45645	1410203	EPA120004		Staten Island	10309	Copper / Pb solder	6/12/2014	6/18/2014	0	0.147

\*Lead = Lead service line

Copper/Pb solder = Copper pipes joined by lead solder installed after 1982.

° See Table 2. Lead and copper compliance samples NOT invalidated but questionable. 10/10/2014

**Table 1. NYC Department of Environmental Protection  
Lead and Copper Selection Criteria and All First Draw Results  
for the compliance period of 2014 and the monitoring period of June - September 2014**

Bottle ID Number	KIT ID Number	Site ID Number	Address of Sampling Site	Borough	Zipcode	Criteria for Inclusion*	Date Collected	Received Date	First Draw at-the-tap Lead level (µg/l)	First Draw at-the-tap copper level (mg/l)
AL-45647	1410205	EPA120007		Staten Island	10303	Copper / Pb solder	6/16/2014	6/17/2014	0	0.104
AL-45648	1410206	EPA120008		Staten Island	10309	Copper / Pb solder	7/2/2014	7/8/2014	0	0.115
AL-45649	1410207	EPA120009		Staten Island	10312	Copper / Pb solder	6/13/2014	6/18/2014	1	0.024
AL-45650	1410208	EPA120010		Staten Island	10312	Copper / Pb solder	6/9/2014	6/10/2014	1	0.106
AL-45651	1410209	EPA120012		Queens	11105	Lead	6/20/2014	6/24/2014	12	0.132
AL-45654	1410212	EPA120015		Staten Island	10306	Copper / Pb solder	6/28/2014	6/30/2014	5	0.166
AL-45655	1410213	EPA120017		Brooklyn	11223	Lead	6/10/2014	6/12/2014	5	0.074
AL-45656	1410214	EPA120019		Manhattan	10075	Lead	7/7/2014	7/10/2014	2	0.071
AL-45661	1410219	EPA120028		Staten Island	10309	Copper / Pb solder	6/10/2014	6/13/2014	0	0.049
AL-45662	1410220	EPA120029		Staten Island	10308	Copper / Pb solder	6/9/2014	6/16/2014	0	0.152
AL-45663	1410221	EPA120031		Staten Island	10310	Copper / Pb solder	6/8/2014	6/16/2014	0	0.150
AL-45664	1410222	EPA120033		Staten Island	10309	Copper / Pb solder	6/15/2014	6/18/2014	2	0.187
AL-45666	1410224	EPA130002		Staten Island	10308	Copper / Pb solder	6/23/2014	6/24/2014	0	0.138
AL-45674	1410232	EPA140007		Brooklyn	11215	Lead	7/13/2014	7/15/2014	59	0.174
AL-45678	1410236	EPA140011		Queens	11412	Lead	6/25/2014	6/26/2014	1	0.041
AL-45679	1410237	EPA943065		Queens	11421	Lead	6/10/2014	6/12/2014	1	0.095
AL-45680	1410238	EPA943282		Bronx	10471	Copper / Pb solder	6/16/2014	6/19/2014	2	0.159
AL-45681	1410239	EPA943646		Brooklyn	11210	Lead	6/12/2014	6/13/2014	5	0.087
AL-45682	1410240	EPA943711		Brooklyn	11218	Lead	6/12/2014	6/13/2014	12	0.086
AL-45683	1410241	EPA954261		Staten Island	10312	Copper / Pb solder	6/14/2014	6/16/2014	4	0.243
AL-45684	1410242	EPA954389		Staten Island	10309	Copper / Pb solder	6/10/2014	6/12/2014	46	0.817
AL-45687	1410245	EPA955349		Brooklyn	11234	Lead	6/14/2014	6/16/2014	5	0.164
AL-45689	1410247	EPA955507		Queens	11432	Lead	6/14/2014	6/17/2014	7	0.248
AL-45690	1410248	EPA95A585		Brooklyn	11236	Copper / Pb solder	6/11/2014	6/16/2014	1	0.114
AL-45691	1410249	EPA95A648		Brooklyn	11209	Copper / Pb solder	6/19/2014	6/23/2014	0	0.040
AL-45692	1410250	EPA97J015		Queens	11432	Lead	6/12/2014	6/16/2014	4	0.122
AL-45693	1410251	EPA997025		Bronx	10462	Lead	6/13/2014	6/23/2014	2	0.123
AL-45694	1410252	EPA997171		Brooklyn	11234	Lead	6/13/2014	6/16/2014	4	0.170
AL-45695	1410253	EPA997230		Bronx	10463	Lead	6/10/2014	6/11/2014	5	0.101
AL-45696	1410254	EPA997875		Queens	11375	Lead	6/11/2014	6/16/2014	7	0.153
AL-45697	1410255	EPA997885		Brooklyn	11232	Lead	6/11/2014	6/16/2014	8	0.126

\*Lead = Lead service line

Copper/Pb solder = Copper pipes joined by lead solder installed after 1982.

° See Table 2. Lead and copper compliance samples NOT invalidated but questionable. 10/10/2014